



North Carolina Department of Environment and Natural Resources

Michael F. Easley, Governor
William G. Ross Jr., Secretary

Division of Waste Management
Underground Storage Tank Section
April 11, 2006

Dexter R. Matthews, Director

Mr. Bryon Smith
5937 Timberwood Trail
Kernersville, NC 27284

Re: Notice of No Further Action
15A NCAC 2L .0407(d)
Risk-based Assessment and Corrective Action
for Petroleum Underground Storage Tanks

Smith Property, Bryon
1455 Union Cross Rd., Kernersville
Forsyth County
Incident Number: 30748
Risk Classification: Low
Ranking: NA

Dear Mr. Smith:

The Tank Closure report received by the Underground Storage Tank (UST) Section, Winston-Salem Regional Office on April 11, 2006 has been reviewed. The review indicates that soil contamination does not exceed the residential maximum soil contaminant concentrations (MSCCs), established in Title 15A NCAC 2L .0411 and that groundwater contamination does not exceed the groundwater quality standards established in Title 15A NCAC 2L .0202.

The UST Section determines that no further action is warranted for this incident. This determination shall apply unless the UST Section later finds that the discharge or release poses an unacceptable risk or a potentially unacceptable risk to human health or the environment. Pursuant to Title 15A NCAC 2L .0407(a) you have a continuing obligation to notify the Department of any changes that might affect the risk or land use classifications that have been assigned.

This No Further Action determination applies only to the subject incident; for any other incidents at the subject site, the responsible party must continue to address contamination as required.

If you have any questions regarding this notice, please contact me at the address or telephone number listed below.

Sincerely,

Cindy Rintoul

Supervisor

Winston-Salem Regional Office